



Dr.-Ing. Friedrich Gottelt

Forschungszentrum für Verbrennungsmotoren und Thermodynamik Rostock

- FVTR Introduction
- LEAG Project Introduction
- Boiler Constructive Overview
- Boiler Model
- Modelling: Problems and Solutions
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- Feedback
- First results calibration
- Summary, outlook

In cooperation with



- **FVTR Introduction**
- LEAG Project Introduction
- Boiler Constructive Overview
- Boiler Model
- Modelling: Problems and Solutions
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- Feedback
- First results calibration
- Summary, outlook


In cooperation with





- Founded in 2007
- 22 colleagues
- Engineering services for **combustion engines** and **energy systems**
  - Measurement
  - Simulation





Experimental  
Engine Research



Exhaust Gas  
Treatment




Fuel Injection  
Analysis



Applied  
Thermodynamics



Energy System  
Simulation



Fuels & Lubricants  
Research



Thermophysical  
Properties



Training, Studies  
& Consulting




# Energy System Simulation

Simulating complex systems for straightforward solutions


## KEY SERVICES

- Modeling of energy sectors and infrastructure
- Dynamic modeling of thermal power plants, maritime energy systems and production processes
- 3D-CFD of combustion and fouling


## POWER PLANT MODELING




## MULTI-ENGINE SYSTEMS



## DISPATCH MODELING




## PARTICLE DEPOSITION



- FVTR Introduction
- **LEAG Project Introduction**
- Boiler Constructive Overview
- Boiler Model
- Modelling: Problems and Solutions
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- Feedback
- First results calibration
- Summary, outlook

## Subject: large lignite power plant

- Operator: **LEAG** 
- Fuel: Lignite
- Live steam approx.: 270 bar / 550 °C
- Hot reheat approx: 60 bar / 580 °C
- District heating: 150 MW<sub>th</sub>






## Scope of Project

- Development of a detailed dynamic model of the power plant
- Shall be used to accompany:
  - Retrofits of the system
  - Changed components
  - Control optimisation
  - Estimate future wear
- Planned investigations:
  - Improvement of primary and secondary control
  - Faster load changes
  - Reduced component stress

- FVTR Introduction
- LEAG Project Introduction
- **Boiler Constructive Overview**
- Boiler Model
- Modelling: Problems and Solutions
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- Feedback
- First results calibration
- Summary, outlook


## General

- Height approx. 176 m
- Benson type boiler
- Fuel: lignite ( 6 -12 MJ/kg)




## Combustion

- Two burner levels
- Primary air and secondary air




## Flue Gas Recirculation

- Recirculated flue gas transports coal
- To dry lignite (water content approach 50 %)
- Approx. 30 % of flue gas flow




## Economiser

- Upmost convective tube bank




## Evaporator and Superheater 1

- Finned tube walls
- Helix in lower parts, upper part has straight pipes
- tube walls in convective part constitute superheater 1
- No wall cooling in the height of the eco



## Superheater 2


- Carrier tubes
- First tube bundle take radiation from the flame room






## Superheater 3 and 4

- Convective tube banks





## Reheat


- Convective tube banks



- FVTR Introduction
- LEAG Project Introduction
- Boiler Constructive Overview
- **Boiler Model**
- **Modelling: Problems and Solutions**
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- Feedback
- First results calibration
- Summary, outlook




- Included:
  - Risers, downcomers
  - StaCy-based initialisation
- Excluded (for now):
  - Headers
- Precise:
  - Gas side heat transfer
- Coarse:
  - Water side heat transfer
  - Pressure losses



## Model Statistics


- Translated Model
  - Constants: 65580 scalars
  - Free parameters: 6943 scalars
  - Parameter depending: 25206 scalars
  - Outputs: 2 scalars
  - Continuous time states: 641 scalars
  - Time-varying variables: 23618 scalars
  - Alias variables: 17077 scalars
  - Assumed default initial conditions: 295
  - Number of mixed real/discrete systems of equations: 0



## Nonlinear systems:

Sizes of nonlinear systems of equations: {20, 20, 20, 20, 20, 20, 20, 20, 20, 20, 20, 20, 20, 3, 3, 10, 2, 20, 20, 20, 3, 3, 10, 3, 2, 2, 20, 5, 3, 3, 10, 2, 2, 4, 10, 3, 10, 3, 2, 2, 3, 2, 2, 3, 3, 10, 2, 2, 10, 2, 2, 3, 10, 2, 2, 3, 4, 20, 3, 3, 3, 3, 10, 2, 10, 2, 2, 10, 2, 2, 2, 6, 2, 2, 3, 8, 2, 2, 3, 8, 2, 2, 2, 8, 3, 2, 2, 8, 3, 2, 2, 8, 3, 2, 3, 15, 2, 2, 7, 7, 7, 3, 3, 3, 3, 3, 3, 7, 2, 10, 2, 10, 2, 2, 10, 2, 2, 3, 7, 7, 7, 7, 7, 10, 2, 10, 10}

## Sizes after manipulation of the nonlinear systems:

[illegible]

- FVTR Introduction
- LEAG Project Introduction
- Boiler Constructive Overview
- Boiler Model
- **Modelling: Problems and Solutions**
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- **Feedback**
- First results calibration
- Summary, outlook

## Nonlinear Systems of Size 4

System simulation.nonlinear[130]:

The equation system depends on the following timevarying variables:

boiler.cooler\_SH2.mixingZone.h

boiler.cooler\_SH2.mixingZone.p

boiler.cooler\_SH2.summary.outline.Delta\_p

boiler.cooler\_SH2.valve.pressureLoss.p\_in

boiler.splitIC2.h

boiler.splitIC2.p


Iteration variables:

boiler.cooler\_SH2.summary.inlet2.T(start = 288.15)

boiler.cooler\_SH2.valve.fluidIn.d(start = 0.0)

boiler.cooler\_SH2.valve.fluidOut.d(start = 0.0)

boiler.cooler\_SH2.valve.fluidOut.T(start = 288.15)





## Problems solved: eliminating lots of nonlinear systems of size 2


System simulation.nonlinear[72]:



The equation system depends on the following timevarying variables:

boiler.RH2.pipeFlow\_FTW.Delta\_p\_grav[4]  
boiler.RH2.pipeFlow\_FTW.h[3]  
boiler.RH2.pipeFlow\_FTW.iCom.h\_in[]  
boiler.RH2.pipeFlow\_FTW.p[3]  
boiler.SH3.pipeFlow\_FTW.Delta\_p\_grav[1]  
boiler.SH3.pipeFlow\_FTW.h[1]  
boiler.SH3.pipeFlow\_FTW.p[1]  
boiler.SH4.pipeFlow\_FTW.p[3]

Iteration variables:


boiler.quadruple10.m\_flow(start =  
boiler.RH2.pipeFlow\_FTW.m\_flow\_nom)  
boiler.RH2.pipeFlow\_FTW.Delta\_p\_fric[4](start = 0.0)







## Realisation of Flue Gas Recirculation

- [illegible]



[illegible]

[illegible]

- FVTR Introduction
- LEAG Project Introduction
- Boiler Constructive Overview
- Boiler Model
- Modelling: Problems and Solutions
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- **Feedback**
- First results calibration
- Summary, outlook

## Feedback

- Model build up of max. complexity is **plannable!**
- Current options for numeric optimisation of Dymola help to get fast models
- Furnace models are not fully physical w.r.t. balance equations and hydraulics
  - Makes models less intuitive in its wiring
  - Problems with reverse flows during initialisation
  - 😊 I solved these problems by try and error of the wiring and strongly reduced initial temperatures at the furnace to prevent reverse flow

## Feedback to Giving Feedback

- Very positive!!
- My feedback is already content of ClaRa 1.4.0
- Share your experience as well! It'll improve ClaRa/ClaRa<sup>+</sup>








- FVTR Introduction
- LEAG Project Introduction
- Boiler Constructive Overview
- Boiler Model
- Modelling: Problems and Solutions
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- Feedback
- **First results calibration**
- **Summary, outlook**

## First Results for Plausibility Check

### Boiler Temperatures








- FVTR Introduction
- LEAG Project Introduction
- Boiler Constructive Overview
- Boiler Model
- Modelling: Problems and Solutions
  - FrictionAtInlet/Outlet between tube bundles and at spray injectors
  - Flue gas recirculation
- Feedback
- First results calibration
- **Summary, outlook**

## Summary

- Boiler model prepared for calibration
- Boiler model and water steam cycle models are optimised w.r.t. numerics
- Controls are currently under development by LEAG

## Outlook

- Calibration of boiler
- Validation of boiler
- Validation of water steam cycle
- Coupling of subsystems with controls
- Validation of complete system
- First investigations





# Perfecting Energy Conversion

---

Your research partner for combustion engines and energy systems

Friedrich Gottelt | [friedrich.gottelt@fvtr.de](mailto:friedrich.gottelt@fvtr.de) | +49 381 4059 662 | [www.fvtr.de](http://www.fvtr.de)